



**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

**1.0 PART 1 - GENERAL**

**1.1 DESCRIPTION**

**1.1.1 SCOPE OF WORK:**

1.1.1.1 The work to be performed under these specifications includes furnishing all labor, materials, tools, and equipment necessary to design, fabricate, construct, inspect and test a fluted column style welded steel elevated water storage tank, including the design and construction of the foundation and accessories as shown on the drawings and specified herein.

1.1.1.2 The work shall also include all labor, new materials, and equipment necessary to clean, paint and disinfect the water storage tank as specified herein.

**1.1.2 RELATED WORK:**

The work shall also include all labor, materials, and equipment necessary to construct the site improvements and site piping as shown on the drawings.

**1.1.3 DESCRIPTION:**

1.1.3.1 The tank and support structure shall be the fluted column style similar to the Hydropillar™ as designed and constructed by CB&I. The tank and support structure shall be of all welded steel design.

1.1.3.2 The tank shall have a dome roof, straight sides, and a coned and dished bottom. Alternatively, a toroidal bottom supported by a dry riser can be provided.

1.1.3.3 To ensure an aesthetically pleasing tank the design of the cone and shell plates shall minimize the number and total length of visible weld seams (shop and field). A scaled plate layout sketch must be provided with the bid or be cause for rejection.

**1.2 PRE-QUALIFICATION OF CONTRACTOR**

1.2.1 Bids will only be accepted from experienced Contractors having a minimum of ten years' experience in the design and construction, using in-house capabilities, of fluted column style elevated tanks of equal or greater capacity. Each bidder shall provide a list of a minimum of ten such tanks that have been in satisfactory operation for at least five years. The list shall include project locations, completion dates, contact names and telephone numbers.

1.2.2 The fluted column style tank and foundation design, welded steel tank fabrication and construction shall be performed by the Contractor's own direct hire employees and shall not be subcontracted in any way. The tank's foundation may be supervised and installed by the Contractor or a qualified local foundation subcontractor.

1.2.3 The Contractor's EMR Rating shall be less than or equal to 0.80. Each bidder shall submit their current EMR letter with the bid, as only Contractors with an EMR less than or equal to 0.80 will be considered. Failure to provide this information, and/or ratings above 0.80 (indicating below average safety standards) shall be cause for rejection of the bid.

**1.3 STANDARDS, CODES AND GUIDES**

The following standards and specifications are referenced. The latest edition shall be used if the edition is not specified.

AWWA D100	Standard for Welded Carbon Steel Tanks for Water Storage
AWWA D102	Standard for Painting Steel Water Storage Tanks
AWWA C652	Standard for Disinfection of Water Storage Facilities
ACI 301	Specifications for Structural Concrete for Buildings
ACI 318	Building Code Requirements for Structural Concrete
NSF 61	Drinking Water System Components



**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

OSHA  
SSPC-PA1

Occupational Safety and Health Standards  
Paint Application Specification

**1.4 OWNER OR ENGINEER SUPPLIED INFORMATION**

The Owner or Engineer shall provide the following information with the bid documents:

- 1.4.1 Geotechnical investigation report that is specific to the site and prepared by a qualified Geotechnical Engineer. The geotechnical investigation report shall include a determination of the Site Class to be used for the structure’s seismic design. The determination of the Site Class shall be in accordance with AWWA D100.
- 1.4.2 Summary of FAA requirements such as height restrictions, obstruction marking or obstruction lighting. The elevated water storage tank may affect navigable airspace. The Owner or Engineer shall file Form 7460-1 with the FAA (<http://forms.faa.gov/>) to determine requirements.

**1.5 SUBMITTALS**

- 1.5.1 Each Bidder shall submit with its proposal a sketch of the fluted column tank showing major dimensions and plate thicknesses. A sketch of the foundation showing preliminary dimensions and approximate quantities of concrete and reinforcing steel shall also be provided with the bid. Failure to provide either of these sketches shall be cause for rejection of the bid.
- 1.5.2 Prior to construction, the Contractor shall furnish construction drawings of the tank, support structure and foundation sealed by a Professional Engineer licensed in the State of \_\_\_\_\_. Construction drawings for the foundation shall show applicable design and construction standards, materials of construction, design loads and allowable soil bearing or pile capacity.
- 1.5.3 A summary of the design for the foundation, support structure and tank shall be provided before construction. The design summary shall show applicable design and construction standards, materials of construction, design loads and results showing conformance with the specifications. The design shall be sealed by a Professional Engineer licensed in the State of \_\_\_\_\_.
- 1.5.4 Welder’s certifications shall be submitted in accordance with AWWA D100.
- 1.5.5 Provide an operating and maintenance manual containing operating instructions, maintenance instructions, as-built construction drawings, cleaning and painting instructions, a gage table and catalog cuts of equipment supplied.

**2.0 PART 2 - PRODUCTS**

**2.1 GENERAL**

Furnish an elevated water storage tank as shown on the drawings and as specified in this section. The design, materials, fabrication, construction, testing and inspection of the tank, support structure and foundation shall comply with AWWA D100, except as modified herein. Tank capacity, head range, height to TCL and top of foundation elevation shall be as shown on the drawings. Tank net capacity shall be \_\_\_\_\_ gallons.

**2.2 DESIGN CRITERIA**

**2.2.1 GENERAL**

- 2.2.1.1 Dead load shall be the estimated weight of all permanent construction and fittings. The unit weight of steel shall be considered as 490 pounds per cubic foot and the unit weight of concrete shall be taken as 144 pounds per cubic foot.

**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

- 2.2.1.2 Water load shall be the weight of the water when the tank is filled to the overflow. The unit weight of water shall be 62.4 pounds per cubic foot.
- 2.2.1.3 The roof snow load shall be in accordance with AWWA D100 and based on a uniform roof load of \_\_\_\_ pounds per square foot.
- 2.2.1.4 Wind loads shall be based on AWWA D100 for an ultimate wind speed,  $V_{ult}$ , of \_\_\_\_ mph and Exposure Category C in accordance with ASCE 7 for Category IV (essential facility) structures.
- 2.2.1.5 Horizontal and vertical seismic loads shall be based on AWWA D100 for Category IV (essential facility) structures, using tank center coordinates of \_\_\_\_ latitude and \_\_\_\_ longitude. The Site Class shall be as specified in the geotechnical report.
- 2.2.1.6 The structural effects of the applied loads shall be considered with the loads defined according to ASCE 7. Load combinations used for allowable stress design and strength design shall conform to AWWA D100.
- 2.2.1.7 The design for all sections of the steel tank shall be per the classes of materials and unit tension/compression stresses specified in AWWA D100. A design per Section 14 of AWWA D100 shall not be permitted.
- 2.2.1.8 Shells designed by Method 2 of Sec. 3.4.3.2 of AWWA D100 shall be measured in accordance with Sec. 11.4.3.2.2 of AWWA D100. Documentation of the measurements and a certificate of compliance shall be provided.
- 2.2.1.9 All openings in the support structure shall be properly reinforced. Loads imposed by openings in the base of the support structure shall be accommodated in the foundation design.
- 2.2.1.10 The overturning moment used in designing the support structure and foundation shall include the moment due to eccentricity of the gravity loads caused by deflection of the structure under wind or seismic conditions (i.e. P-Delta effect).
- 2.2.1.11 Unless otherwise noted, at junctions in plates where meridional forces are discontinuous such as cone to cylinder junctions, a tension or compression ring may be required to resist the radial forces generated. In these regions, the allowable stresses shall not exceed those specified in AWWA D100.
- 2.2.1.12 No corrosion allowance is required unless specified in Section 7.9 herein.

**2.2.2 FOUNDATION**

- 2.2.2.1 The design of the foundation shall conform to ACI 318 except as modified herein.
- 2.2.2.2 The foundation design shall be by the Contractor and shall conform to the recommendations given in the geotechnical report. The foundation depth shall be as required for the extreme frost penetration shown in AWWA D100.
- 2.2.2.3 Earth cover shall be a minimum of \_\_\_\_ feet over top of pipe in accordance with AWWA D100. Any pipe passing through the foundation which does not meet this minimum cover requirement shall be properly insulated until such minimum cover is achieved.
- 2.2.2.4 Unless modified by the Geotechnical Engineer, shallow foundations shall be sized to provide a safety factor of 3.0 against the ultimate soil bearing capacity in accordance with AWWA D100. For deep foundations, the safety factor shall be as required by AWWA D100 Table 20. When direct vertical loads are combined with wind or seismic, the safety factor for shallow foundations may be reduced to 2.25, and the safety factor for deep foundations shall follow AWWA D100 Table 20.
- 2.2.2.5 The foundation shall be sized such that there is a minimum safety factor of 1.5 against overturning for wind or seismic events using service load combinations.
- 2.2.2.6 Foundation piling shall conform to the design and detailing requirements of International Building Code (IBC) Section 1810, including the supplemental design and detailing requirements based on the assigned Seismic Design Category (SDC).

**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

**2.3 APPURTENANCES****2.3.1 EXTERIOR DOORS**

- 2.3.1.1 Provide one 36-inch x 84-inch commercial steel door, 1 $\frac{3}{4}$ " thick, 4 $\frac{3}{4}$ " 16-gauge jamb, industrial duty type door closer and automatic door bottom. Door to be Deansteel or approved equal. Door shall be minimum 16-gauge and insulated with pre-formed polystyrene insulation. Door shall be thoroughly cleaned, phosphated and finished with one coat of baked-on rust inhibiting primer in accordance with ASTM B117 and ASTM D1735. Provide three (3) full mortise, 5 knuckle hinges, 4 $\frac{1}{2}$ " x 4 $\frac{1}{2}$ " minimum. Hinges shall be steel, phosphated and primed coated for finish painting. Provide a complete and functional door lockset and tumbler-type lock, keyed to the owner's existing system. Door painting shall conform to the tank exterior paint system.
- 2.3.1.2 Provide one manually operated \_\_\_\_-foot wide by \_\_\_\_ foot high overhead steel rolling door located in the base of the support structure. Door slats shall be formed of 22-gauge steel with end locks and designed for a minimum 20-psf wind load. Steel curtain construction with high-grade zinc coating per ASTM A153 hot process, and phosphate coating for paint adhesion. Provide air baffle for entire upper barrel, curtain bottom bar with brush sealing, weather end lock on alternate slats and sealing strips for weather tightness. The door shall be equipped with slide bolt locks on both sides of interior bottom. Overhead door location shall be as shown on the drawings.
- 2.3.1.3 Provide two (2) 8-inch diameter steel safety posts on the exterior of the overhead door opening to protect the door from vehicle impact. Safety posts shall be filled with concrete.

**2.3.2 PIPING & PRESSURE RELIEF**

- 2.3.2.1 A \_\_\_\_-inch diameter inlet/outlet pipe shall be provided from the bottom of the tank to a flanged connection at the base of the support structure. The inlet/outlet pipe shall be steel with welded connections and have a thickness not less than 1/4 inch. Flexibility to accommodate differential movements may be provided by an expansion joint or by piping layout with sufficient offset to deform without overstressing the pipe. Provide taps as shown on the drawings.
- 2.3.2.2 The inlet/outlet pipe shall extend a minimum of six inches above the bottom of the tank floor or be equipped with a removable silt stop.
- 2.3.2.3 A \_\_\_\_-inch diameter overflow pipe equipped with an anti-vortex entrance detail shall be provided. The overflow shall be designed to accommodate the maximum inlet rate specified in Section 2.3.2.4. The overflow pipe shall be steel with welded connections. The overflow shall be attached to the access tube and support structure, and discharge at a point approximately two feet above finish grade onto a splash block. The end of the overflow shall be covered with No. 4 galvanized steel wire mesh screen.
- 2.3.2.4 At least one aluminum pressure-vacuum vent near the roof's center shall be provided. The vent(s) shall be sized to handle pressure differential caused by water entering or leaving the tank at a maximum rate. The maximum inlet rate is \_\_\_\_\_ gpm, and the maximum withdrawal rate is \_\_\_\_\_ gpm. The open area of the overflow shall not be considered as a venting area. The vent(s) shall have insect screens and shall be designed to relieve pressure or vacuum if the screen frosts over or is clogged and shall be easily dismantled for cleaning. The vent(s) shall be self-correcting. The pressure-vacuum vent may be mounted on the exhaust hatch.

**2.3.3 ACCESS, LADDERS & PLATFORMS**

- 2.3.3.1 Provide a ladder system attached to the support structure, which extends from grade to the walkway and painters access manhole. This ladder system shall be offset with rest platforms provided. Rest platforms shall have a hinged cover at the ladder opening.
- 2.3.3.2 Provide a ladder on the interior of the access tube from the walkway to the tank roof, and from the walkway to the tank bottom manhole. These ladders shall be equipped with ladder safety cables.
- 2.3.3.3 The ladder safety cable shall be an OSHA approved, galvanized system as manufactured by DBI-Sala, or equal. Provide a removable extension for each ladder that does not extend 48 inches beyond the walkway level. The Owner shall be supplied with 2 harnesses, 2 lanyards and 2 sleeves.



**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

- 2.3.3.4 Provide a walkway immediately below the tank extending from the support structure to the access tube. The walkway shall be a minimum of 48 inches wide with 42-inch high handrails.
- 2.3.3.5 Provide an access tube located on the vertical centerline of the tank. The access tube shall have a minimum diameter of 48 inches and shall provide access from the walkway to the tank roof. The platform at the bottom of the access tube shall have a 24-inch diameter opening with hinged cover for future containment rigging.

**2.3.4 MANHOLES, HATCHES & VENTS**

- 2.3.4.1 One 30-inch diameter painter's access manhole shall be provided giving access to the exterior painter's rail located at the top of the support structure. There shall be a platform inside the support structure at this point.
- 2.3.4.2 One 30-inch diameter tank bottom manhole shall be provided in the tank bottom with access by ladder from the walkway.
- 2.3.4.3 Two 32-inch diameter steel hatches shall be supplied. One shall be at the top of the access tube with spring assist, chain, hook, and inside handle. The other shall be adjacent to the access tube for entry into the tank and shall have a handle and hasp. The hatch openings shall have a curb four inches high and the cover shall have a downward overlap of two inches.
- 2.3.4.4 One 24-inch diameter flanged exhaust hatch shall be supplied, located adjacent to the access tube and so constructed that an exhaust fan may be connected for ventilation during painting.
- 2.3.4.5 One 24-inch diameter painter's access manhole shall be provided adjacent to each interior painter's rail giving access from the roof. The 24-inch diameter exhaust hatch may be positioned to serve as one of these access manholes.
- 2.3.4.6 A minimum of eight (8) vents, 10 inches in diameter, shall be provided in the support structure. Half of the vents shall be installed near the top of the support structure and the other half near the base. If the tank is equipped with a condensate ceiling, the lower vents shall be located above the condensate ceiling.

**2.3.5 PAINTER'S RAILS**

Provide painter's rails and an interior inspection rail as shown on the drawings and specified herein:

- 2.3.5.1 Interior Painters Rails. The rails shall be attached to the underside of the roof. Provide one rail near the center of the tank and one rail approximately 18 inches from the tank shell. If the slope distance between these two rails exceeds 32 feet, provide a third rail near midspan.
- 2.3.5.2 Exterior Painters Rail. The rail shall be located near the top of the support structure and be accessible from the walkway via the painter's access manhole.

**2.3.6 ELECTRICAL**

Interior waterproof light sockets with rigid conduit, wiring and switch shall be provided inside the support structure and access tube. Total number and location of lights shall be as shown on the drawings. All wiring shall be in conduit. The conduit and wiring shall terminate with a junction box in the base of the support structure. Duplex outlets shall be installed as shown on the drawings. Electric service shall be provided and connected by others.

**2.3.7 GALVANIC CORROSION PROTECTION**

Dissimilar metals (e.g., stainless steel, copper, and brass) more noble than carbon steel and installed inside the tank below the TCL shall be electrically isolated from carbon steel tank components to which they attach. Painting of the dissimilar metals does not eliminate the requirement for isolation.

**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

**3.0 PART 3 – EXECUTION****3.1 INSPECTION**

Inspection and testing shall be in accordance with of AWWA D100. Shop subassembly welds that require radiographic inspection shall be inspected in the shop or field. If radiographic inspection is performed in the shop, radiographs shall be provided to the Engineer prior to their delivery to the jobsite.

**3.2 CONCRETE FOUNDATION**

3.2.1 If, during excavation, conditions are encountered which differ from those given in the geotechnical report, appropriate adjustments to construction schedule and price will be negotiated.

3.2.2 An inlet/outlet pipe extending a minimum of three feet outside the foundation wall shall be included as part of the foundation.

3.2.3 Provide a 6-inch-thick concrete slab at grade in the base of the support structure. The slab shall be placed over compacted structural backfill and shall be reinforced with welded wire reinforcement. Provide 1/2-inch expansion material at the slab to foundation intersection and at floor penetrations. Provide saw-cut control joints at 18 feet maximum spacing. The slab shall be sloped towards the floor drain. The slab shall be constructed in accordance with the latest edition of ACI 301.

3.2.4 All concrete work shall comply with ACI 301.

**3.3 WELDING**

3.3.1 All welding shall comply with AWWA D100.

3.3.2 All welding procedures, welders and welding operators shall be qualified in accordance with ASME Section IX for the processes and positions utilized.

3.3.3 To minimize corrosion and rust staining on the underside of the roof, the underside roof plate laps and rafter-to-roof plate seams shall be seal welded. The minimum thickness for seal welded roof plates shall be 1/4 inch.

3.3.4 The girth seams of the support structure shall be butt-welded, and the vertical seams shall be continuous fillet lap-welded on the exterior only.

3.3.5 The edges or surfaces of the pieces to be joined by welding shall be prepared by flame cutting, plasma arc cutting, arc gouging, machining, shearing, grinding, or chipping and shall be cleaned of detrimental oil, grease, scale and rust. The edges of the pieces may have a protective coating applied to them which need not be removed before they are welded unless specifically prohibited by the welding procedures.

3.3.6 Field and shop welding may be done by the shielded metal arc welding process, the gas metal arc welding process, the flux core arc welding process, and the submerged arc welding process.

3.3.7 Plates and component members of the tank shall be assembled and welded following erection methods which result in a minimum of distortion from weld shrinkage. Surfaces to be welded shall be free from loose scale, slag, heavy rust, grease, paint, and other foreign material.

3.3.8 Full penetration butt-welded joints shall be inspected using the radiographic examination method. The number and location of the radiographs and the acceptance criteria shall be as required by AWWA D100. Inspection by sectional segments is not allowed.

**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

- 3.3.9 When the cone plate thickness has been determined using a nonlinear buckling analysis, the contractor shall measure the actual imperfections of the cone plates after welding. The measurements shall be taken in the meridional direction. Measurements shall be taken at each meridional weld seam and midway between each meridional weld seam. Where the actual imperfections exceed the tolerances assumed in the analysis, further evaluation will be required and corrective action such as reworking the shell or adding stiffeners may be required.
- 3.3.10 To assist in the maximization of the paint's lifecycle, all welds on the tank exterior shall be ground smooth and blended to a NACE-D profile. All welds on the tank interior shall be ground smooth and blended to a NACE-D profile. Welds on the interior dry support column can remain in an as-welded condition but must have a profile adequate for the specified paint system. Engineer/Owner reserves the right to provide third-party inspection to ensure compliance to this requirement.

**4.0 PART 4 – COATINGS & FINISHES****4.1 GENERAL**

- 4.1.1 All tank painting and paint testing shall be in accordance with AWWA D102, the Steel Structures Painting Council Specification SSPC-PA1, approved paint manufacturer specifications and as specified herein.
- 4.1.2 Each system shall be from a single manufacturer.
- 4.1.3 Pre-construction full-thickness shop primers may be utilized in the fabrication process to preserve the blast profile and cleanliness. In the field, weld seams and abraded areas will be cleaned on a spot basis. The remaining sound primer will be cleaned to remove dirt and other contaminants. After cleaning, the specified coating system will be applied in its entirety in the field at the thickness (mils) specified.
- 4.1.4 No paint shall be applied when the temperature of the surface to be painted is below the minimum temperature specified by the paint manufacturer, or less than 5 degrees above the dew point temperature. Paint shall not be applied to wet or damp surfaces or when the relative humidity exceeds 85% unless allowed by manufacturer's data sheets. Follow the paint manufacturer's recommendations for the specific paint system used.
- 4.1.5 After erection and before painting, remove slag, weld metal splatter and sharp edges by chipping or grinding. All surfaces that have been welded, abraded, or otherwise damaged, shall be cleaned and primed in the field in accordance with the paint system requirements.
- 4.1.6 All areas blasted in the field shall be coated before any rusting occurs.

**4.2 EXTERIOR COATING SYSTEM**

- 4.2.1 Shop Surface Preparation: Spot clean as required to remove all oil and grease from the surface prior to blast cleaning. All surfaces shall be abrasive blast cleaned to a commercial finish in accordance with the recommended methods outlined in the Steel Structures Painting Council Specification SSPC SP-6/NACE No. 3.
- 4.2.2 Shop Primer: Immediately after abrasive blasting and before any rusting occurs apply one coat of zinc rich aliphatic urethane to a dry film thickness (DFT) range of 2.5 to 3.5 mils.
- 4.2.3 Field Surface Preparation for Blast Cleaning: After erection and prior to field touch-up priming, all surfaces shall be cleaned to remove all surface contamination including oil, grease, dust, dirt, and foreign matter. Chip or grind as required to remove all slag, weld metal splatter and sharp edges.
- 4.2.4 Field Blast Cleaning: All rusted, abraded, and bare metal / unpainted areas shall be blast cleaned to a commercial finish in accordance with SSPC SP-6/NACE No. 3. All shop primed areas shall be brush blasted to SSPC SP-7/NACE No. 4



**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

- 4.2.5 Field Touch-Up: Spot prime with zinc rich aliphatic urethane to a DFT range of 2.5 to 3.5 mils.
- 4.2.6 Field Intermediate Coat: Apply one coat of Hi-build epoxy, to a DFT range of 2.0 to 3.0 mils. The color shall be tinted to contrast the prime coat.
- 4.2.7 Field Finish Coat: Apply one coat of gloss finish polyurethane, to a DFT range of 2.0 to 3.0 mils. Finish color shall be selected by the Owner.
- 4.2.8 The total DFT range of the three coat Exterior Paint System shall be 6.5 to 9.5 mils.
- 4.3 INTERIOR WET COATING SYSTEM
  - 4.3.1 Shop Surface Preparation: Spot clean as necessary to remove all oil and grease from the surface prior to blast cleaning. All surfaces shall be abrasive blast cleaned to a near-white finish in accordance with SSPC SP-10/NACE No. 2.
  - 4.3.2 Shop Primer: Immediately after abrasive blasting and before any rusting occurs, apply one coat of zinc rich aliphatic urethane, to a DFT range of 2.5 to 3.5 mils.
  - 4.3.3 Field Surface Preparation for Blast Cleaning: After erection and prior to field touch-up priming, all surfaces shall be spot cleaned as required to remove all surface contamination including oil, grease, dust, dirt and foreign matter. Chip or grind as required to remove all slag, weld metal splatter and sharp edges.
  - 4.3.4 Field Blast Cleaning: All rusted, abraded, and bare metal / unpainted areas shall be blast cleaned to a near white finish in accordance with SSPC SP-10/NACE No. 2. All shop primed areas shall be brush blasted to SSPC SP-7/NACE No. 4
  - 4.3.5 Field Touch-Up: spot prime with zinc rich aliphatic urethane, to a DFT range of 2.5 to 3.5 mils.
  - 4.3.6 Irregular surfaces, including weld seams, bolt heads and nuts, corners, and edges, shall be stripe coated by brush or roller after the field spot prime coat has been applied and prior to application of the first full field coat.
  - 4.3.7 Field Intermediate Coat: Apply one coat of Immersion approved epoxy, to a DFT range of 2.0 to 3.0 mils. The color shall be tinted to contrast the prime coat.
  - 4.3.8 Field Finish Coat: Apply one coat of Immersion approved epoxy, to a DFT range of 4.0 to 6.0 mils.
  - 4.3.9 The total DFT range of the Interior Paint System shall be 8.0 to 10.0 mils.
  - 4.3.10 Interior immersion surfaces will be holiday tested per NACE SP0188.
- 4.4 INTERIOR DRY COATING SYSTEM
  - 4.4.1 Shop Surface Preparation: Spot clean as necessary to remove all oil and grease from the surface prior to blast cleaning. All surfaces shall be abrasive blast cleaned to a commercial finish in accordance with SSPC SP-6/NACE No. 3.
  - 4.4.2 Shop Primer: Immediately after abrasive blasting and before any rusting occurs, apply one coat of zinc rich aliphatic urethane, to a DFT range of 2.5 to 3.5 mils.
  - 4.4.3 Field Surface Preparation for Blast Cleaning: After erection and prior to field touch-up priming, all surfaces shall be spot cleaned as required to remove all surface contamination including oil, grease, dust, dirt, and foreign matter. Chip or grind as required to remove all slag, weld metal splatter and sharp edges.





**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

- 4.4.4 Field Blast Cleaning: All rusted, abraded, and bare metal / unpainted areas shall be blast cleaned to a commercial finish in accordance with SSPC SP-6/NACE No. 3. All shop primed areas shall be brush blasted to SSPC SP-7/NACE No. 4
- 4.4.5 Field Touch-Up: Spot prime with zinc rich aliphatic urethane, to a DFT range of 2.5 to 3.5 mils.
- 4.4.6 Field Finish Coat: Apply one coat of Hi-build epoxy, to a DFT range of 3.0 to 5.0 mils.
- 4.4.7 The total DFT range of the Interior Paint System shall be 6.0 to 8.0 mils.

**4.5 LETTERING AND LOGO**

Lettering and Logo design, size and location shall be as indicated on the drawings. Lettering/Logo shall be applied using one coat of high gloss polyurethane. Lettering / Logo color shall be selected by the Owner.

**5.0 PART 5 - TESTING AND STERILIZATION**

- 5.1 Sufficient cure, per the manufacturer's recommendations, of the final coat on the interior wet surface shall be allowed before the elevated tank is sterilized and filled with water.
- 5.2 The tank shall be sterilized per the requirements of AWWA C652. Chlorination Method No. 2 or 3.
- 5.3 The Owner, free of charge to the Contractor, shall furnish and dispose of sufficient water for testing and sterilization. The water shall be at proper pressure to fill the tank to the maximum working level. Any leaks in the tank that are disclosed by this test shall be repaired by gouging out defective areas and re-welding. No repair work shall be done on any joint unless the water in the tank is at least 2 feet below the joint being repaired. Any paint damaged by repairs shall be properly restored.
- 5.4 Upon completion of the sterilization procedure, the Owner or his representative shall arrange and bear the cost of any bacteriological testing of water samples from the tank that may be required. The tank shall not be placed in service until safe test results are obtained.

**6.0 PART 6 - GUARANTEE**

- 6.1 The Contractor shall guarantee its work for a period of one year from the date of substantial completion. Substantial completion is defined as the date when the tank is placed, or available to be placed, into service. The Contractor will repair any defects of which they are notified during that period which may appear because of faulty design, workmanship or materials furnished under the specifications. Defects caused by damaging service conditions such as electrolytic, chemical, abrasive, or other damaging service conditions are not covered by this guarantee.
- 6.2 All guarantees and extended warranties offered by the manufacturer or installer of paint, equipment or accessories not manufactured by the Contractor shall be obtained by the Owner directly from the manufacturer or installer. The Owner shall provide the Contractor a copy of all such guarantees and warranties.

SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION

---

**7.0 PART 7 - PURCHASER OPTIONS / ALTERNATIVES**

***The following items are to replace or append paragraphs within the specification by the Engineer / Owner prior to issuing specification for bidding:***

**7.1 EXTERIOR DOORS**

- 7.1.1 Additional access doors may be added for locations where multiple entry points are required.
- 7.1.2 Alternate materials of construction and operation can be specified for access doors and overhead doors. Overhead doors may be insulated and/or specified with motor-controlled operation (including remote control).

**7.2 INSULATION ROOM AND RISER PIPE INSULATION**

- 7.2.1 For the vertical riser piping, starting at the ceiling of the insulated enclosure up to the tank bottom, provide \_\_\_-inch thick molded rigid foam polyisocyanurate insulation complete with vapor barrier on inlet/outlet pipe. Securely fasten the insulation to the pipe using aluminum banding.
- 7.2.2 Provide insulated enclosure, by Extreme Panel Technologies, or approved equal, as a full enclosure for the horizontal floor piping and valves, as shown on Contract Drawings.

**7.3 COMPLETE TANK DRAINAGE**

- 7.3.1 A 3-inch diameter non-freeze drain valve (Babco or equal) shall penetrate the tank at the low point of the tank bottom and connect to the overflow pipe. An NSF approved flexible pipe shall be used to connect the drain valve to the overflow pipe.

**7.4 ACCESS, LADDERS & PLATFORMS**

- 7.4.1 A ladder for access to the tank interior from the roof, shall be provided and attached to the access tube. (Note: this is not recommended in cold climates where freezing may occur). This ladder shall be equipped with ladder safety cable.
- 7.4.2 Provide a 42-inch high circular roof handrail, 20 feet in diameter, to encompass all centrally located roof appurtenances. The roof handrail shall be 42 inches high and shall include a top rail, intermediate rail, and toe board. The handrail must be constructed to meet all OSHA requirements.

**7.5 MANHOLES, HATCHES & VENTS**

For installations where mechanical equipment such as pumps and motors or chlorination equipment will be located in the base of the support structure, reinforced openings for vents and louvers shall be per drawings.

**7.6 ELECTRICAL**

- 7.6.1 Exterior lighting shall be provided above the access door(s) and/or overhead door(s) for added security, and exterior lighting around the base of the support structure at ground level to illuminate the tank and/or support structure for aesthetic effect, per drawings.
- 7.6.2 In accordance with the Purchaser's FAA Determination Letter, a double obstruction light shall be provided on the roof of the tank near the apex. The lights shall be enclosed in aviation red obstruction light globes as approved by the FAA, complete with an automatic photo-electric cell type switch. The Contractor shall install all conduit and wiring from the light to the electrical service panel.

**7.7 GRAVEL FLOOR**

The interior of the support structure base shall be finished with a six (6) inch thick crushed stone or gravel floor.



**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

All excavated areas under the crushed stone or gravel floor shall be backfilled with suitable material and compacted to 90 percent maximum dry density.

**7.8 FLOORS**

- 7.8.1 Provide a structural floor located as shown on the drawings. The floor shall be designed for a minimum uniform live load of \_\_\_\_\_ psf and shall consist of a concrete slab supported by formed galvanized steel decking and galvanized steel girders. The floor shall be a clear span design supported entirely by the support structure wall. Loads transferred from structural floors to support structure shall be considered in the design of the foundation.
- 7.8.2 Construct stairs and platforms using steel channel for the stair stringers and framing members. Treads shall be formed from checkered plate complete with supporting brackets welded to the stringers. All stair and platform components shall be painted same as interior dry paint system
- 7.8.3 Provide a wall mounted jib crane with a 1-ton load capacity and 12-foot span. The jib crane shall be equipped with a 1-ton manual chain hoist and trolley. Locate the jib crane as shown on the drawings.
- 7.8.4 Provide a 48-inch x 48-inch square aluminum hatch embedded in the structural floor located as shown on the drawings.
- 7.8.5 The Contractor shall make provisions in the design of the support structure and foundation for installing additional floors at a future date with a minimum uniform live load of \_\_\_\_\_ psf.
- 7.8.6 This responsibility is limited to meeting only the structural requirements for the additional loads on the support structure and foundation. Provisions for future penetrations of the support structure are not required. Any architectural requirements such as plumbing, electrical, fire exits, etc. needed to meet building code requirements for fire rating for using the structure for anything other than as an elevated water tank are excluded.

**7.9 CORROSION ALLOWANCE**

A corrosion allowance of 1/16 inch shall be applied to tank plates in direct contact with the stored water. The corrosion allowance shall be added to the required thickness determined by design.

**7.10 ANTENNA RAIL AND CABLE DETAILS**

- 7.10.1 Provide all labor, materials, equipment, and installation to make all necessary provisions for future antenna cable(s) routing. This work includes but is not limited to the following:
  - 7.10.1.1 Three (3) 4.5-inch outside diameter pipe penetrations (with caps) in the support structure, located approximately two feet (2') above the tank floor.
  - 7.10.1.2 Three (3) 4.5-inch outside diameter pipe penetrations in the condensate ceiling and platform.
  - 7.10.1.3 Three (3) 4.5-inch outside diameter pipe penetrations (with caps) in the access tube cover.
  - 7.10.1.4 Suitable brackets welded to the inside of the support structure and access tube to safely secure future antenna cables. Bracket spacing shall not exceed 8 feet.
- 7.10.2 For safety considerations during antenna installation, and for maintenance, a 42" high circular roof handrail shall be furnished with a top rail, intermediate rail, and toe board. Handrail shall be 20 feet in diameter and centered on the tank access tube roof hatch. The handrail shall also provide an attachment point for antenna(s), based on the antenna quantity and loads provided in this specification.

**7.11 TANK MIXING SYSTEM**

- 7.11.1 Furnish and erect a passive tank mixing system.



**SECTION 33 16 13 HYDROPILLAR™ ELEVATED TANK SPECIFICATION**

---

- 7.11.2 The storage tank mixing system shall accomplish thorough mixing of the tank contents. The mixing system shall function without the use of mechanical pumps, blowers, or other equipment with motor drives or other continuously moving parts. The energy needed to mix the storage tank shall be provided solely by the flow of water through the tank inlet pipe, based on the following fill rate of \_\_\_\_\_ gpm. The mixing system shall distribute the fresh, newly-disinfected incoming water throughout the tank, reducing microbial growth and related tastes and odors.
  
- 7.12 CROW'S NEST
  - 7.12.1 Provide a 3 foot wide crow's nest platform around the access tube inside the tank above the TCL for tank inspection. The crow's nest shall have a solid floor with sealed raised edges, designed to prevent contamination from shoe scrapings and dirt., and a 42" high handrail all around. Provide opening in the access tube to the crow's nest platform. Provide tank access ladder from the platform with a chained opening to the ladder.